

Part 1: GENERAL

1.1 **Scope:** Subject to local building codes, this product is intended for use in:

- 1.1.1 Single family dwelling interior applications.
- 1.1.2 Multifamily dwelling, low-rise professional office, library and low-rise motel interior applications.
- 1.1.3 Lighter use industrial building and factory, hotel, and retail sales building interior applications.

1.2 **Product Description:** 1-3/4" or 1-3/8" side-hinged door systems manufactured by MASONITE.

1.2.1 Door system components include: door panel(s), bifold panel(s), door frame, hinges.

Part 2: BASIC MATERIALS

2.1 **Door Panel:** Masonite® Molded Panel doors shall be fabricated using loose lay up assembly that includes molded wood fiber facings, wood or MDF stiles, wood or MDF rails and corrugated cell core. Door facings are to be bonded to stiles, rails and core forming a 3-ply structural attachment. Water based latex primer used on door facings (stile and rails per request) unless factory pre-finished.

2.1.1 Mounting surface for latching hardware to be reinforced with solid internal support. Hinge preparations for 1-3/8" thick doors to be machined for standard weight radius mortise 3-1/2" hinges and 1-3/4" thick doors to be machined to accept 4" hinges. Latch preparations are to be placed in the area of solid internal supports. Face bore(s) for cylindrical lock and deadbolt are to be 2-1/8" diameter at 2-3/4" or 2-3/8" backset.

2.1.2 Vertical edge of door to be square, beveled both sides or lock stile only. Edge preparation should be clearly noted when the product is ordered.

2.2 **Bifold Panel:** Masonite® Molded Panel bifolds shall be fabricated using loose lay up assembly that includes molded wood fiber facings with optional flush facings on backside, wood or MDF stiles, wood or MDF rails and corrugated cell. Bifold facings are to be bonded to stiles, rails and core forming a 3-ply structural attachment.

2.3 **Door Frame:** Wood jambs shall be fabricated as a flat jamb with doorstop applied or 2-piece split jamb. Hinge jamb preparations for 1-3/8" thick doors to be machined for standard weight radius mortise 3-1/2" hinges and 1-3/4" thick doors to be machined to accept 4" hinges. Strike jamb preparations are to be machined for full lip cylindrical strike plate. Double door units shall include preparations for ball catch located at the top of door on both door panels designed to strike into the head jamb.

2.4 **Hinges:** (3) standard weight radius mortise hinges are required on doors 7'0" height or smaller & (4) on doors greater than 7'0".


Part 3: DELIVERY, STORAGE & HANDLING

3.1 **Delivery:** Reasonable care shall be exercised during shipping and handling in keeping with the decorative nature of product.

3.2 **Storage & Protection:** Store upright in a dry, well ventilated building or shelter at a constant temperature. Do not store in damp, freshly plastered, drywall or concrete areas until materials have completely dried. Doors should be stored at least 10' away from any heat source to help prevent uneven drying. Doors must be sealed with an oil-based sealer or primer if stored for long periods.

Part 4: EXECUTION

4.1 **Examination:** Site verification of substrate conditions, which have been previously completed, are acceptable for the product installation instructions in accordance with manufacturer's specifications. Verify that door frame openings are constructed plumb, true and level before



beginning installation process. Select fasteners of adequate type, number and quality to perform the intended functions.

4.2 **Installation:** Remove protective packaging just prior to installation. Installer shall be experienced in performing work required and shall be specialized in the installation of work similar to that required for this project. Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions and product packaging instructions for installation.

4.3 **Finishes:** See Masonite - How To Paint instructions for complete finishing details. Various types of materials are used in the construction of the door system; each shall be sealed in accordance with manufacturer's specifications to protect against various environmental conditions. Make sure to completely seal and inspect all 6-surfaces (top, hinge side, bottom, lock side, front face and back face) with two coat minimum on operable panel(s). Finishing and/or re-finishing must be completed immediately after door has acclimated to the environment where it is to be installed and within a maximum of 7 days. Avoid finishing after a rain or damp and during periods of higher than average humidity. Conduct periodic inspections of all coated surfaces to insure that door components are not exposed. Inspections should occur at least once a year. Reseal the surface as needed.

Part 5: GENERAL PERFORMANCE

5.1 **Acoustical Performance:** Unit scheduled for installation in opening requiring a specific noise control rating shall be clearly noted when product is ordered. 1-3/8" thick Molded Panel Series door with corrugated core sound transmission class (STC) rating is 26. (See acoustical performance data for unit specific acoustical information.)

Part 6: WARRANTY

6.1 Limited 1-Year - Please check with manufacturer or distributor for current warranty terms and conditions.